

EXHIBIT D

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
3	PG&E	01/01/17	15:57	38.66287	-121.74803	Vegetation	Urban	< 3 Meters	Fire Agency	Woodland fire dept 530-666-8920	101589774	Unknown	0 – 750	Conductor	Overhead	Yes	1/1/17	15:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
4	PG&E	01/10/17	15:55	38.75380	-121.15641	Building	Urban	Structure Only	Unknown	N.A.	100065079	Unknown	12,000	Conductor	Overhead	Yes	1/10/17	15:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
5	PG&E	01/18/17	15:34	37.38388	-121.80884	Building	Urban	Structure Only	Unknown	Unknown	100564835	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	1/18/17	15:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
6	PG&E	01/29/17	09:45	38.36159	-121.95091	Building	Urban	Structure Only	Fire Agency	Unknown	18550	Unknown	12,000	Transformer	Subsurface	Yes	1/29/17	09:45	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
7	PG&E	02/03/17	10:00	37.58153	-122.02772	Vegetation	Urban	< 3 Meters	Fire Agency	jeff	100938466	Unknown	12,000	Conductor	Overhead	Yes	2/3/17	10:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
8	PG&E	02/07/17	04:50	38.43314	-122.71902	Building	Urban	Structure Only	Fire Agency	Santa Rosa Fire Dept	102014637	PACIFIC BELL	12,000	Conductor	Overhead	Yes	2/7/17	04:50	Other	N.A.	N.A.	N.A.	Unknown	
9	PG&E	03/16/17	12:43	38.27175	-122.01971	Other	Urban	< 0.25 Acres	Fire Agency	Unknown	101561532	PACIFIC BELL	12,000	Conductor	Overhead	Yes	3/16/17	12:43	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
10	PG&E	03/17/17	09:37	38.11532	-121.42216	Other	Rural	Structure Only	Fire Agency	911	102044732	PACIFIC BELL	21,000	Conductor	Overhead	Yes	3/17/17	09:37	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
11	PG&E	03/19/17	17:06	38.76209	-121.85247	Vegetation	Urban	< 3 Meters	Fire Agency	CHICO FIRE DEPT 911	100441377	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	3/19/17	17:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
12	PG&E	03/23/17	07:04	37.36975	-121.85218	Other	Urban	< 3 Meters	Fire Agency	SJFD disp 408-277-8950	103485262	Unknown	12,000	Transformer	Subsurface	Yes	3/23/17	07:04	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
13	PG&E	03/28/17	12:15	34.88092	-120.41992	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	103397961	YES	12,000	Conductor	Overhead	Yes	3/28/17	12:15	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
14	PG&E	04/01/17	14:54	37.18823	-120.95764	Vegetation	Rural	< 0.25 Acres	Fire Agency	engine 74 mrced fire agency	102318665	Unknown	12,000	Conductor	Overhead	Yes	4/1/17	14:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
15	PG&E	04/04/17	13:29	35.68851	-120.78533	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101945026	None	12,000	Conductor	Overhead	Yes	4/4/17	13:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
16	PG&E	04/04/17	14:54	37.29584	-121.93295	Vegetation	Urban	< 3 Meters	Customer	N.A.	100591136	None	12,000	Conductor	Overhead	Yes	4/4/17	14:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
17	PG&E	04/10/17	16:35	35.61751	-119.74296	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	100128630	Unknown	21,000	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
18	PG&E	04/13/17	14:21	37.79671	-121.25210	Other	Urban	Structure Only	Fire Agency	MANTECA CITY	102104500	VERIZON CALIFO	17,000	Conductor	Overhead	Yes	4/13/17	14:21	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
19	PG&E	04/16/17	15:14	35.85053	-119.14227	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103833904	Unknown	12,000	Conductor	Overhead	Yes	4/16/17	15:14	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
20	PG&E	04/20/17	20:14	37.37407	-120.17688	Vegetation	Urban	< 3 Meters	Fire Agency	209-966-3621	101205903	Unknown	12,000	Transformer	Overhead	No			Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
21	PG&E	04/23/17	7:10	36.07345	-120.93450	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101726333	Unknown	12,000	Conductor	Overhead	Yes	4/23/17	7:10	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
22	PG&E	04/24/17	11:52	38.18990	-121.15129	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101718868	None	12,000	Conductor	Overhead	Yes	4/24/17	11:52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	tie wire
23	PG&E	04/25/17	12:38	38.65832	-120.97622	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101376746	Unknown	0 – 750	Transformer	Overhead	Yes	4/25/17	12:38	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
24	PG&E	04/25/17	18:26	36.23725	-119.78071	Other	Rural	Structure Only	Self Extinguished	N.A.	100716676	Unknown	0 – 750	Conductor	Overhead	Yes	4/25/17	18:26	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
25	PG&E	04/26/17	15:55	38.15608	-121.67886	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT KENNY WILLIAMS (707)374-2233	103826165	Unknown	21,000	Conductor	Overhead	Yes	4/26/17	15:55	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
26	PG&E	04/28/17	5:55	34.58848	-120.10568	Vegetation	Rural	< 0.25 Acres	Fire Agency	805-683-2724	101900122	Unknown	12,000	Conductor	Overhead	Yes	4/28/17	5:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
27	PG&E	04/28/17	14:35	37.12469	-121.62488	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	103098414	Unknown	0 – 750	Conductor	Overhead	Yes	4/28/17	14:35	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
28	PG&E	04/28/17	15:49	38.76786	-120.96253	Vegetation	Rural	< 0.25 Acres	Fire Agency	chris paper fire investigator, 530/677-1868, incident #caaeuo11821	101409833	PACIFIC BELL	21,000	Conductor	Overhead	Yes	4/28/17	15:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
29	PG&E	04/29/17	15:07	37.03486	-119.52423	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100678661	Unknown	12,000	Conductor	Overhead	Yes	4/29/17	15:07	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
30	PG&E	04/30/17	9:32	35.63491	-118.95629	Vegetation	Rural	< 0.25 Acres	Fire Agency	661-324-6551	100216308	Unknown	21,000	Conductor	Overhead	Yes	4/30/17	9:32	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
31	PG&E	05/01/17	14:20	36.02289	-119.95837	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	CORCORAN STATION 559-992-2156	Pole 076/015	Unknown	70,000	Conductor	Overhead	Yes	5/1/17	14:20	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
32	PG&E	05/03/17	10:04	36.81613	-119.63202	Vegetation	Rural	< 0.25 Acres	Fire Agency	eng 44 Eric connors 559-324-2294	100770906	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/3/17	10:04	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
33	PG&E	05/03/17	12:51	38.19080	-121.68150	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103834798	Unknown	21,000	Conductor	Overhead	Yes	5/3/17	12:51	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
34	PG&E	05/04/17	16:19	35.55728	-120.75348	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101934476	Unknown	12,000	Conductor	Overhead	Yes	5/4/17	16:19	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
35	PG&E	05/05/17	15:52	40.37758	-123.00187	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101501566	None	12,000	Conductor	Overhead	Yes	5/5/17	15:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
36	PG&E	05/06/17	1:56	37.32997	-120.83297	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103834182	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	1:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
37	PG&E	05/06/17	11:18	40.79512	-124.02902	Vegetation	Rural	< 3 Meters	Fire Agency	chief rick harden 7074423352	103661154	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	11:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
38	PG&E	05/06/17	12:43	40.76227	-124.16195	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100998152	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	12:43	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
39	PG&E	05/06/17	15:00	39.24580	-123.77854	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	102185559	Unknown	12,000	Conductor	Overhead	Yes	5/6/17	15:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
40	PG&E	05/06/17	23:46	36.16537	-120.37372	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100741510	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/6/17	23:46	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
41	PG&E	05/09/17	11:15	40.05970	-122.18895	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101531151	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/9/17	11:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
42	PG&E	05/09/17	15:57	39.54650	-121.85667	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100404826	Unknown	12,000	Conductor	Overhead	No			Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
43	PG&E	05/09/17	18:26	40.86892	-123.51559	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	todd wright fire chief, 5307392493	103796045	Unknown	12,000	Conductor	Overhead	Yes	5/9/17	18:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
44	PG&E	05/12/17	15:16	38.85066	-121.31683	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102347828	Unknown	21,000	Conductor	Overhead	Yes	5/12/17	15:16	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
45	PG&E	05/13/17	21:49	39.67845	-121.77802	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	103355502	Unknown	12,000	Conductor	Overhead	Yes	5/13/17	21:49	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
46	PG&E	05/14/17	11:59	38.07980	-122.86650	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	102247059	PACIFIC BELL	12,000	Conductor	Overhead	Yes	5/14/17	11:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
47	PG&E	05/14/17	16:09	35.60167	-119.65665	Vegetation	Rural	10 - 99 Acres	Fire Agency	661-391-7000	100131572	Unknown	21,000	Conductor	Overhead	Yes	5/14/17	16:09	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
48	PG&E	05/15/17	3:05	35.62610	-120.89616	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101873299	Unknown	21,000	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
49	PG&E	05/15/17	13:05	38.19694	-121.40951	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102071491	Unknown	12,000	Transformer	Overhead	No			Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
50	PG&E	05/15/17	16:00	37.17665	-119.81887	Vegetation	Rural	< 0.25 Acres	Fire Agency	SHAUN FAIRBANKS 559-683-4823	101108423	SIERRA	21,000	Conductor	Overhead	Yes	5/15/17	16:00	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
51	PG&E	05/15/17	20:57	38.67253	-122.04559	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101589358	Unknown	21,000	Conductor	Overhead	Yes	5/15/17	20:57	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
52	PG&E	05/16/17	17:21	35.37590	-119.14413	Vegetation	Urban	< 0.25 Acres	Fire Agency	324-6551	103264300	Unknown	12,000	Conductor	Overhead	Yes	5/16/17	17:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
53	PG&E	05/17/17	14:49	37.22500	-120.48326	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101154662	Unknown	12,000	Transformer	Overhead	Yes	5/17/17	14:49	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	Transformer fuse
54	PG&E	05/17/17	15:13	36.24862	-121.03830	Other	Rural	10 - 99 Acres	Fire Agency	Unknown	101764465	None	12,000	Conductor	Overhead	Yes	5/17/17	15:13	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
55	PG&E	05/19/17	9:37	40.03343	-122.09887	Vegetation	Rural	< 0.25 Acres	Fire Agency	INCIDENT NUMBER 004751	101534483	Unknown	0 – 750	Conductor	Overhead	Yes	5/19/17	9:37	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	secondary riser
56	PG&E	05/19/17	10:52	37.20861	-121.09683	Vegetation																		

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
68	PG&E	05/31/17	2:06	38.75403	-121.22378	Vegetation	Rural	< 0.25 Acres	Fire Agency	Placer Co. fire	100063341	ROSEVILLE	12,000	Conductor	Overhead	Yes	5/31/17	2:06	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
69	PG&E	05/31/17	5:24	37.02750	-120.07067	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101113852	Unknown	12,000	Conductor	Overhead	Yes	5/31/17	5:24	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
70	PG&E	06/01/17	9:11	40.18301	-122.26654	Vegetation	Rural	< 0.25 Acres	Fire Agency	MARK FRITZ	101546068	Unknown	12,000	Conductor	Overhead	Yes	6/1/17	9:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
71	PG&E	06/01/17	21:35	41.05570	-121.38690	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101550337	FRONTIER COMM	12,000	Conductor	Overhead	Yes	6/1/17	21:35	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
72	PG&E	06/01/17	22:34	36.65394	-121.62918	Vegetation	Rural	< 3 Meters	Fire Agency	Saltinas FD	101732360	Unknown	12,000	Lightning Arrestor	Overhead	Yes	6/1/17	22:34	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
73	PG&E	06/03/17	13:26	38.90174	-121.20569	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100043664	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/3/17	13:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
74	PG&E	06/03/17	20:52	36.83229	-119.63327	Vegetation	Rural	< 3 Meters	Fire Agency	CLOVIS F.D. CHIEF	100768082	Unknown	12,000	Conductor	Overhead	Yes	6/3/17	20:52	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
75	PG&E	06/04/17	00:08	36.98200	-120.03471	Vegetation	Rural	< 0.25 Acres	Fire Agency	Mike Gomez 559 906-1621 Incident #17cammu011185	103837406	None	12,000	Conductor	Overhead	Yes	6/4/17	00:08	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
76	PG&E	06/04/17	13:12	36.74591	-120.06018	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100645872	Unknown	12,000	Conductor	Overhead	Yes	6/4/17	13:12	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
77	PG&E	06/05/17	0:52	38.23420	-121.21311	Vegetation	Rural	< 3 Meters	Unknown	N.A.	102083982	PACIFIC BELL	12,000	Transformer	Overhead	Yes	6/5/17	0:52	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
78	PG&E	06/05/17	7:56	37.85680	-120.88150	Vegetation	Rural	< 0.25 Acres	Fire Agency	209 5523911	102333651	None	17,000	Conductor	Overhead	Yes	6/5/17	7:56	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
79	PG&E	06/05/17	17:12	36.94243	-121.46123	Vegetation	Rural	10 - 99 Acres	Fire Agency	Leo Alvarez 831-6364324	101717332	Unknown	21,000	Conductor	Overhead	Yes	6/5/17	17:12	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
80	PG&E	06/06/17	9:15	36.45426	-119.13382	Vegetation	Rural	< 0.25 Acres	Fire Agency	TIM ROGERS, 559-358-7120	102306658	Unknown	12,000	Conductor	Overhead	Yes	6/6/17	9:15	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
81	PG&E	06/06/17	09:48	36.99857	-120.93690	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	101199765	Unknown	12,000	Conductor	Overhead	Yes	6/6/17	09:48	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
82	PG&E	06/06/17	13:39	38.17110	-121.67825	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101666655	FRONTIER COMM	21,000	Fuse	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
83	PG&E	06/07/17	13:25	35.09398	-119.41607	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100192567	Unknown	12,000	Conductor	Overhead	No			Contact From Object	N.A.	Animal	Electric Facility	Unknown	
84	PG&E	06/07/17	10:13	39.56030	-122.10768	Vegetation	Rural	< 3 Meters	Utility: PG&E	N.A.	103838281	Unknown	12,000	Conductor	Overhead	Yes	6/7/17	10:13	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
85	PG&E	06/08/17	5:33	36.23884	-120.30164	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	100743822	Unknown	12,000	Conductor	Overhead	Yes	6/8/17	5:33	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
86	PG&E	06/08/17	0:26	37.12759	-120.01930	Vegetation	Rural	100 - 299 Acres	Fire Agency	Jeff Mc Carroll (559) 806 - 8915	103205823	Unknown	12,000	Conductor	Overhead	Yes	6/8/17	0:26	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
87	PG&E	06/08/17	15:08	34.60580	-120.02140	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	SHAWN STEINER	101947678	Unknown	12,000	Conductor	Overhead	Yes	6/8/17	15:08	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
88	PG&E	06/09/17	10:40	36.69563	-119.71863	Vegetation	Rural	< 0.25 Acres	Fire Agency	FRESNO COUNTY	100793555	Unknown	12,000	Conductor	Overhead	Yes	6/9/17	10:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
89	PG&E	06/09/17	13:27	36.73820	-119.82038	Vegetation	Rural	< 0.25 Acres	Fire Agency	FFD INC # 703 4018	100895732	Unknown	12,000	Conductor	Overhead	Yes	6/9/17	13:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
90	PG&E	06/09/17	17:20	35.79741	-120.53892	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	103406061	Unknown	12,000	Conductor	Overhead	Yes	6/9/17	17:20	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
91	PG&E	06/10/17	07:37	35.43590	-120.49570	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101890429	Unknown	21,000	Conductor	Overhead	Yes	6/10/17	07:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
92	PG&E	06/12/17	15:28	36.96720	-120.09309	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101136946	Unknown	12,000	Conductor	Overhead	Yes	6/12/17	15:28	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
93	PG&E	06/12/17	18:04	35.36381	-118.82556	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	103371824	Unknown	12,000	Transformer	Overhead	Yes	6/12/17	18:04	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
94	PG&E	06/13/17	14:30	37.85265	-122.18529	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	Tower 005/035c	Unknown	115,000	Conductor	Overhead	Yes	6/13/17	14:30	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	third-party caused
95	PG&E	06/14/17	22:23	39.75591	-121.59343	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100324481	PACIFIC BELL	12,000	Fuse	Overhead	Yes	6/14/17	22:23	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
96	PG&E	06/15/17	2:58	40.29899	-122.43185	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101511631	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/15/17	2:58	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	power theft
97	PG&E	06/15/17	5:02	36.82613	-121.67456	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101712958	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/15/17	5:02	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
98	PG&E	06/15/17	7:39	39.22756	-121.23476	Vegetation	Rural	< 0.25 Acres	Fire Agency	FIRE CHIEF	103676075	Unknown	21,000	Conductor	Overhead	Yes	6/15/17	7:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
99	PG&E	06/15/17	15:01	39.39127	-123.30541	Vegetation	Rural	< 0.25 Acres	Fire Agency	STEPHEN	103838176	YES	12,000	Conductor	Overhead	Yes	6/15/17	15:01	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
100	PG&E	06/15/17	16:21	38.70880	-122.90160	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101957366	Unknown	0 - 750	Conductor	Overhead	Yes	6/15/17	16:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
101	PG&E	06/15/17	17:18	38.79696	-121.20690	Vegetation	Urban	< 0.25 Acres	Fire Agency	Cal Fire	100058437	Unknown	21,000	Conductor	Overhead	Yes	6/15/17	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
102	PG&E	06/16/17	13:50	35.45950	-120.61690	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101989864	Unknown	21,000	Conductor	Overhead	Yes	6/16/17	13:50	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
103	PG&E	06/16/17	14:22	36.84496	-120.01919	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	101212782	Unknown	0 - 750	Conductor	Overhead	Yes	6/16/17	14:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
104	PG&E	06/16/17	16:17	39.22280	-121.00411	Vegetation	Rural	< 3 Meters	Fire Agency	GVFIRE	100036908	Unknown	12,000	Conductor	Overhead	Yes	6/16/17	16:17	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	third-party caused
105	PG&E	06/16/17	17:59	37.30938	-122.04719	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100555441	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/16/17	17:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
106	PG&E	06/16/17	19:14	38.34429	-122.78122	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101970781	Unknown	0 - 750	Conductor	Overhead	Yes	6/16/17	19:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
107	PG&E	06/16/17	22:30	38.03734	-122.18465	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101424286	Unknown	21,000	Conductor	Overhead	Yes	6/16/17	22:30	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
108	PG&E	06/17/17	02:53	37.33567	-120.58295	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101147424	Unknown	12,000	Conductor	Overhead	Yes	6/17/17	02:53	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
109	PG&E	06/17/17	15:49	36.93896	-119.68463	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	103406061	Unknown	21,000	Conductor	Overhead	Yes	6/17/17	15:49	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
110	PG&E	06/18/17	23:49	39.19494	-122.96321	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102160857	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	23:49	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
111	PG&E	06/18/17	12:22	36.72578	-119.79068	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100894729	PACIFIC BELL	0 - 750	Conductor	Overhead	Yes	6/18/17	12:22	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
112	PG&E	06/18/17	13:10	38.23703	-122.67015	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102007208	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/18/17	13:10	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
113	PG&E	06/18/17	18:09	37.55165	-122.29253	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	103039893	Unknown	21,000	Conductor	Overhead	Yes	6/18/17	18:09	Equipment/ Facility Failure	Guy/Span Wire	N.A.	N.A.	Unknown	
114	PG&E	06/18/17	20:16	38.88844	-122.02044	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101650987	None	12,000	Lightning Arrestor	Overhead	Yes	6/18/17	20:16	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
115	PG&E	06/18/17	21:07	37.83974	-121.28643	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102085809	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	21:07	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
116	PG&E	06/18/17	22:12	38.53900	-122.79203	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	102029435	Unknown	12,000	Other	Overhead	Yes	6/18/17	22:12	Equipment/ Facility Failure	Voltage Regulator	N.A.	N.A.	Unknown	
117	PG&E	06/18/17	23:12	36.75747	-119.66455	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100780126	PACIFIC BELL	12,000	Conductor	Overhead	No			Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
118	PG&E	06/18/17	23:31	38.89731	-121.29467	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103782395	Unknown	12,000	Conductor	Overhead	Yes	6/18/17	23:31	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
119	PG&E	06/19/17	01:23	35.36762	-118.95521	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100252360	PACIFIC BELL	21,000	Conductor	Overhead	Yes	6/19/17	01:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
120	PG&E	06/19/17	13:51	39.90633	-122.17660	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	103841797	YES	12,000	Conductor	Overhead	Yes	6/19/17	13:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	third-party caused
121	PG&E	06/19/17	16:18	37.79272	-121.23058																			

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Fire Suppressed by	Fire Suppressing Agency	Facility Identification	Utility Facility Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
141	PG&E	06/23/17	13:00	39.30510	-122.48618	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	100329817	Unknown	0 – 750	Conductor	Overhead	Yes	6/23/17	13:00	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	power theft
142	PG&E	06/23/17	20:09	40.38565	-122.28408	Vegetation	Urban	< 0.25 Acres	Fire Agency	kieth foster 530-347-4737	101505644	Unknown	12,000	Conductor	Overhead	Yes	6/23/17	20:09	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	Booster bank
143	PG&E	06/23/17	19:23	39.78294	-121.86700	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100397376	None	12,000	Conductor	Overhead	Yes	6/23/17	19:23	Contact From Object	N.A.	Animal	N.A.	Unknown	
144	PG&E	06/24/17	10:31	38.94379	-121.04466	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100090318	PACIFIC BELL	12,000	Transformer	Overhead	Yes	6/24/17	10:31	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
145	PG&E	06/24/17	14:51	38.36218	-120.76381	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101255656	Unknown	12,000	Fuse	Overhead	Yes	6/24/17	14:51	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
146	PG&E	06/24/17	22:27	38.29083	-120.84900	Vegetation	Rural	10 - 99 Acres	Fire Agency	CONTACT BOBBY BOWMAN	101238865	None	12,000	Conductor	Overhead	Yes	6/24/17	22:27	Contact From Object	N.A.	Animal	N.A.	Unknown	
147	PG&E	06/25/17	18:18	37.32357	-120.55914	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101159230	Unknown	12,000	Conductor	Overhead	Yes	6/25/17	0.7625	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
148	PG&E	06/25/17	0:23	39.40434	-123.38687	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101293088	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/25/17	0:23	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
149	PG&E	06/25/17	6:02	39.07743	-121.52937	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101314125	Unknown	12,000	Conductor	Overhead	Yes	6/25/17	6:02	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
150	PG&E	06/25/17	15:37	34.93950	-119.69246	Vegetation	Rural	100 - 299 Acres	Fire Agency	805-686-5074	100191652	None	12,000	Conductor	Overhead	Yes	6/25/17	15:37	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
151	PG&E	06/25/17	22:14	39.02503	-121.57873	Vegetation	Rural	< 3 Meters	Fire Agency	Olivehurst FD	101314072	Unknown	21,000	Conductor	Overhead	Yes	6/25/17	22:14	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
152	PG&E	06/26/17	8:18	37.27331	-120.52573	Vegetation	Rural	< 0.25 Acres	Self Extinguished	N.A.	103218794	Unknown	12,000	Conductor	Overhead	Yes	6/26/17	8:18	Contact From Object	N.A.	Vehicle	N.A.	Human Error	Third-party caused
153	PG&E	06/26/17	14:29	35.97817	-120.11694	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	HENNAGIN 559 386 555	103243976	Unknown	21,000	Conductor	Overhead	Yes	6/26/17	14:29	Contact From Object	N.A.	Animal	N.A.	Unknown	
154	PG&E	06/27/17	9:23	37.95588	-122.61762	Vegetation	Rural	10 - 99 Acres	Fire Agency	marin county fire	102260068	UNFILED	12,000	Conductor	Overhead	Yes	6/27/17	9:23	Contact From Object	N.A.	N.A.	N.A.	Unknown	
155	PG&E	06/27/17	17:47	39.51264	-122.20333	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100341056	None	21,000	Conductor	Overhead	Yes	6/27/17	17:47	Contact From Object	N.A.	Animal	N.A.	Unknown	
156	PG&E	06/28/17	09:57	35.90555	-120.84214	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	101765453	Unknown	12,000	Conductor	Overhead	No			Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
157	PG&E	06/28/17	13:09	34.92757	-119.62041	Building	Rural	Structure Only	Fire Agency	(805)683-2724	100190548	Unknown	21,000	Conductor	Overhead	Yes	6/28/17	13:09	Contact From Object	N.A.	Vehicle	N.A.	Human Error	Third-party caused
158	PG&E	06/29/17	18:31	38.44450	-122.89990	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102021185	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	6/29/17	18:31	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
159	PG&E	06/29/17	21:55	35.98040	-121.09557	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	103312369	Unknown	12,000	Transformer	Overhead	Yes	6/29/17	21:55	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
160	PG&E	06/30/17	10:24	39.02621	-121.54317	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101341770	Unknown	21,000	Conductor	Overhead	Yes	6/30/17	10:24	Contact From Object	N.A.	Animal	N.A.	Unknown	
161	PG&E	06/30/17	01:20	39.82098	-121.58834	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103840463	YES	12,000	Conductor	Overhead	Yes	6/30/17	01:20	Contact From Object	N.A.	Vehicle	N.A.	Human Error	Third-party caused
162	PG&E	06/30/17	23:54	38.57941	-122.88349	Vegetation	Rural	< 3 Meters	Customer	N.A.	101958904	PACIFIC BELL	12,000	Conductor	Overhead	Yes	6/30/17	23:54	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
163	PG&E	07/01/17	12:02	39.82093	-121.64183	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	Pole 003/039	Unknown	60,000	Conductor	Overhead	Yes	7/1/17	12:02	Contact From Object	N.A.	Animal	N.A.	Unknown	
164	PG&E	07/01/17	3:54	36.99950	-119.97648	Vegetation	Rural	< 0.25 Acres	Fire Agency	2099663621	101015895	Unknown	0 – 750	Conductor	Overhead	Yes	7/1/17	3:54	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
165	PG&E	07/01/17	3:12	38.19517	-122.91971	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103855493	Unknown	12,000	Conductor	Overhead	Yes	7/1/17	3:12	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
166	PG&E	07/01/17	10:41	39.27788	-121.68748	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101294919	Unknown	12,000	Other	Overhead	Yes	7/1/17	10:41	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
167	PG&E	07/02/17	13:28	38.86055	-121.62736	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	Pole 000/017c	Unknown	60,000	Conductor	Overhead	Yes	7/2/17	13:28	Contact From Object	N.A.	Animal	N.A.	Unknown	
168	PG&E	07/02/17	3:49	36.95878	-120.89268	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101205043	Unknown	12,000	Conductor	Overhead	Yes	7/2/17	3:49	Contact From Object	N.A.	Balloons	N.A.	Human Error	Third-party caused
169	PG&E	07/03/17	20:26	38.79229	-120.94384	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101388730	PACIFIC BELL	21,000	Conductor	Overhead	Yes	7/3/17	20:26	Contact From Object	N.A.	Animal	N.A.	Unknown	
170	PG&E	07/04/17	13:56	40.38303	-122.31503	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101506140	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/4/17	13:56	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
171	PG&E	07/04/17	16:16	38.87628	-121.13185	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100050181	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	7/4/17	16:16	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
172	PG&E	07/04/17	20:16	40.42283	-122.39748	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	SCOTT CORN 530-448-2414	101481860	Unknown	0 – 750	Conductor	Overhead	Yes	7/4/17	20:16	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
173	PG&E	07/05/17	3:25	38.68451	-121.01176	Vegetation	Urban	< 0.25 Acres	Fire Agency	JUSTIN RHAMES	101380157	PACIFIC BELL	21,000	Fuse	Overhead	Yes	7/5/17	3:25	Contact From Object	N.A.	Animal	N.A.	Unknown	
174	PG&E	07/05/17	11:58	39.21046	-121.22662	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	STEVE ROBERTSON 530 906 4892	100010286	Unknown	21,000	Conductor	Overhead	Yes	7/5/17	11:58	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
175	PG&E	07/05/17	20:54	35.68475	-120.10996	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	N.A.	100171224	Unknown	21,000	Capacitor Bank	Overhead	No			Contact From Object	N.A.	Animal	N.A.	Unknown	
176	PG&E	07/06/17	15:18	36.74020	-119.76128	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	100864107	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	7/6/17	15:18	Contact From Object	N.A.	Vegetation	N.A.	Human Error	Third-party caused
177	PG&E	07/06/17	14:02	39.30091	-122.51726	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100414219	Unknown	12,000	Conductor	Overhead	Yes	7/6/17	14:02	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
178	PG&E	07/06/17	20:07	39.59874	-121.90989	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100436921	None	12,000	Conductor	Overhead	Yes	7/6/17	20:07	Contact From Object	N.A.	Vehicle	N.A.	Human Error	Third-party caused
179	PG&E	07/06/17	23:30	35.55618	-120.75520	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101934472	Unknown	21,000	Conductor	Overhead	Yes	7/6/17	23:30	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
180	PG&E	07/07/17	15:09	40.90536	-122.38061	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	101455950	Unknown	12,000	Conductor	Overhead	Yes	7/7/17	15:09	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
181	PG&E	07/07/17	14:31	37.49900	-119.79900	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	STEVEN WARD OFFICE 209-966-3542 CELL559-706-8811	103855637	Unknown	21,000	Conductor	Overhead	Yes	7/7/17	14:31	Contact From Object	N.A.	Vegetation	N.A.	Human Error	PG&E contractor
182	PG&E	07/08/17	4:03	38.55354	-121.53680	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101584938	Unknown	0 – 750	Conductor	Overhead	Yes	7/8/17	4:03	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
183	PG&E	07/08/17	15:59	37.28217	-122.01887	Other	Urban	< 0.25 Acres	Fire Agency	Unknown	100540958	Unknown	0 – 750	Conductor	Overhead	Yes	7/8/17	15:59	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
184	PG&E	07/08/17	18:16	35.46529	-120.67132	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	103392970	Unknown	0 – 750	Conductor	Overhead	Yes	7/8/17	18:16	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
185	PG&E	07/08/17	18:49	40.29354	-122.40890	Vegetation	Rural	10 - 99 Acres	Fire Agency	TOM STROING, RED BLUFF	101526269	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/8/17	18:49	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
186	PG&E	07/09/17	7:07	36.50920	-121.44651	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103011964	Unknown	12,000	Conductor	Overhead	Yes	7/9/17	7:07	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
187	PG&E	07/09/17	11:00	39.42015	-121.54390	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100394209	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/9/17	11:00	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
188	PG&E	07/10/17	09:07	38.20742	-121.23350	Vegetation	Rural	< 3 Meters	Customer	N.A.	102083900	Unknown	0 – 750	Conductor	Overhead	Yes	7/10/17	09:07	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
189	PG&E	07/10/17	12:32	40.26028	-123.82528	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103139646	Unknown	12,000	Conductor	Overhead	Yes	7/10/17	12:32	Contact From Object	N.A.	Vegetation	N.A.	Unknown	
190	PG&E	07/10/17	16:39	36.96201	-120.85839	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	EFRAIN CHAVARRIA	101203174	Unknown	12,000	Conductor	Overhead	Yes	7/10/17	16:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
191	PG&E	07/10/17	17:00	37.37677	-122.35967	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	David Hibdon 831-254-1763	100270370	Unknown	12,000	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	N.A.	Unknown	
192	PG&E	07/11/17	8:11	38.13370	-121.10542	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102072316	None	21,000	Other	Overhead	Yes	7/11/17	8:11	Contact From Object	N.A.	Animal	N.A.	Unknown	
193	PG&E	07/11/17	11:53	38.03382	-121.32243	Vegetation	Urban	< 0.25 Acres	Utility: PG&E	N.A.	102118581	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	7/11/17	11:53	Wire-Wire Contact	N.A.	N.A.	N.A.	Unknown	
194	PG&E	07/11/17	13:56	39.																				

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Fire Suppressed by	Fire Suppressing Agency	Facility Identification	Utility Facility Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
208	PG&E	07/15/17	21:01	38.21284	-121.83399	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101658237	Unknown	21,000	Conductor	Overhead	Yes	7/15/17	21:01	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
209	PG&E	07/16/17	10:39	40.34139	-123.87861	Vegetation	Rural	< 3 Meters	Fire Agency	707-726-1280	100990019	Unknown	12,000	Conductor	Overhead	Yes	7/16/17	10:39	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
210	PG&E	07/16/17	11:59	36.66692	-121.75148	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101761892	None	21,000	Fuse	Overhead	Yes	7/16/17	11:59	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
211	PG&E	07/16/17	12:10	35.66129	-120.92200	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101942626	Unknown	21,000	Conductor	Overhead	Yes	7/16/17	12:10	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
212	PG&E	07/16/17	17:01	37.34415	-122.03630	Vegetation	Urban	< 3 Meters	Fire Agency	sunmyvale fire	100532224	PACIFIC BELL	0 - 750	Transformer	Overhead	Yes	7/16/17	17:01	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
213	PG&E	07/17/17	07:39	40.16532	-122.22279	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101543908	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/17/17	07:39	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
214	PG&E	07/17/17	10:00	35.95605	-120.85152	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101765495	Unknown	12,000	Conductor	Overhead	Yes	7/17/17	10:00	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
215	PG&E	07/17/17	18:58	38.88853	-121.98984	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Dunnigan Fire Dept	101602915	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/17/17	18:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
216	PG&E	07/18/17	11:30	38.04843	-120.55653	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	Structure 012/071	Unknown	115,000	Conductor	Overhead	Yes	7/18/17	11:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
217	PG&E	07/18/17	21:40	38.00311	-122.20926	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	Pole 000/002 to 000/003	Unknown	60,000	Conductor	Overhead	Yes	7/18/17	21:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
218	PG&E	07/18/17	07:39	38.07038	-120.54518	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101269434	Unknown	0 - 750	Other	Overhead	Yes	7/18/17	07:39	Other	N.A.	N.A.	Unknown		
219	PG&E	07/18/17	11:45	36.83081	-119.86228	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100624764	PACIFIC BELL	21,000	Capacitor Bank	Overhead	Yes	7/18/17	11:45	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
220	PG&E	07/19/17	5:52	37.09047	-119.60469	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Tower 003/001	Unknown	115,000	Conductor	Overhead	Yes	7/19/17	5:52	Contact From Object	N.A.	Other	Electric Facility	Unknown	
221	PG&E	07/19/17	09:33	35.34462	-118.86086	Vegetation	Rural	< 3 Meters	Unknown	N.A.	100159158	Unknown	12,000	Capacitor Bank	Overhead	Yes	7/19/17	09:33	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
222	PG&E	07/19/17	17:19	39.41242	-123.81234	Vegetation	Rural	< 0.25 Acres	Fire Agency	DRUE RHOADS 707 964 5673	102201550	YES	12,000	Conductor	Overhead	Yes	7/19/17	17:19	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
223	PG&E	07/20/17	20:57	37.73609	-122.49208	Building	Urban	Structure Only	Unknown	N.A.	101813719	Unknown	0 - 750	Conductor	Overhead	Yes	7/20/17	20:57	Wire-Wire Contact	N.A.	N.A.	Unknown		
224	PG&E	07/20/17	01:46	36.52545	-119.68200	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100830639	Unknown	0 - 750	Lightning Arrestor	Overhead	Yes	7/20/17	01:46	Equipment/ Facility Failure	Lightning Arrestor	N.A.	N.A.	Unknown	
225	PG&E	07/20/17	04:27	38.06420	-120.87106	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	chris costales 209 754 2735	102142834	Unknown	12,000	Conductor	Overhead	Yes	7/20/17	04:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
226	PG&E	07/20/17	13:45	35.08036	-120.55383	Vegetation	Rural	10 - 99 Acres	Fire Agency	PAUL LEE 805 903-3416 INC # 8291	101941116	Unknown	12,000	Conductor	Overhead	Yes	7/20/17	13:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
227	PG&E	07/20/17	17:00	37.92651	-121.23203	Vegetation	Urban	< 3 Meters	Customer	N.A.	103384380	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	7/20/17	17:00	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
228	PG&E	07/21/17	13:27	38.26884	-120.93718	Vegetation	Rural	.26 - 9.99 Acres	Unknown	N.A.	101245524	Unknown	12,000	Conductor	Overhead	Yes	7/21/17	13:27	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
229	PG&E	07/21/17	20:26	41.06550	-121.39320	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101549629	Unknown	12,000	Conductor	Overhead	Yes	7/21/17	20:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
230	PG&E	07/22/17	12:25	40.87950	-123.76380	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Josh ,comander chief of forest service.	100980577	Unknown	12,000	Conductor	Overhead	Yes	7/22/17	12:25	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
231	PG&E	07/22/17	14:38	37.99945	-122.16306	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	100265488	Unknown	12,000	Conductor	Overhead	Yes	7/22/17	14:38	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
232	PG&E	07/22/17	16:01	40.83143	-124.05389	Vegetation	Rural	< 0.25 Acres	Fire Agency	BATTALION CHIEF CURT WATKINS, 707-825.2000	100983827	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/22/17	16:01	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
233	PG&E	07/23/17	09:22	40.64201	-122.23025	Vegetation	Rural	< 0.25 Acres	Fire Agency	CAPT?	101459708	FRONTIER COMM	12,000	Conductor	Overhead	Yes	7/23/17	09:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
234	PG&E	07/23/17	16:32	36.24055	-119.81283	Vegetation	Rural	< 0.25 Acres	Fire Agency	Brandon Jones (559) 852-2884	100783832	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	16:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
235	PG&E	07/23/17	18:25	39.67233	-123.53360	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103823226	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	18:25	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
236	PG&E	07/23/17	19:41	36.21714	-119.90973	Vegetation	Rural	< 0.25 Acres	Fire Agency	Brandon Jones (559) 852-2884	103846605	Unknown	12,000	Conductor	Overhead	Yes	7/23/17	19:41	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
237	PG&E	07/24/17	14:01	37.26349	-122.33643	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike klunk 650-879-0121	100322130	Unknown	0 - 750	Conductor	Overhead	Yes	7/24/17	14:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
238	PG&E	07/24/17	16:07	37.25369	-121.96760	Vegetation	Urban	< 0.25 Acres	Fire Agency	CA170250039	103447162	Unknown	0 - 750	Conductor	Overhead	Yes	7/24/17	16:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
239	PG&E	07/24/17	19:31	38.33692	-120.71036	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101262632	Unknown	12,000	Conductor	Overhead	Yes	7/24/17	19:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
240	PG&E	07/24/17	21:45	36.60243	-120.92107	Vegetation	Rural	10 - 99 Acres	Unknown	N.A.	101860186	Unknown	12,000	Conductor	Overhead	Yes	7/24/17	21:45	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
241	PG&E	07/25/17	15:51	38.37795	-122.53878	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	102031447	Unknown	12,000	Conductor	Overhead	Yes	7/25/17	15:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
242	PG&E	07/25/17	19:12	39.59970	-121.44490	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100403812	Unknown	12,000	Conductor	Overhead	Yes	7/25/17	19:12	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
243	PG&E	07/26/17	06:55	36.78124	-119.75525	Vegetation	Urban	< 3 Meters	Fire Agency	FRESNO FIRE, BATALION 1, FULMER 559 993 2661	100866522	PACIFIC BELL	12,000	Conductor	Overhead	Yes	7/26/17	06:55	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
244	PG&E	07/28/17	14:02	40.99973	-121.95793	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101512624	Unknown	12,000	Conductor	Overhead	Yes	7/28/17	14:02	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
245	PG&E	07/28/17	16:57	35.47270	-120.99080	Vegetation	Rural	10 - 99 Acres	Fire Agency	TOM MCEWEN 805-903-3409	101933868	Unknown	12,000	Conductor	Overhead	Yes	7/28/17	16:57	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
246	PG&E	07/28/17	19:20	35.72756	-120.99030	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	San Luis Obispo CDF	101945496	None	21,000	Conductor	Overhead	Yes	7/28/17	19:20	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
247	PG&E	07/29/17	13:18	39.46313	-121.45951	Vegetation	Rural	< 0.25 Acres	Fire Agency	russ fowler 530 521 8056	103846763	Unknown	12,000	Conductor	Overhead	Yes	7/29/17	13:18	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
248	PG&E	07/29/17	13:28	35.45229	-120.38344	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101889516	Unknown	0 - 750	Conductor	Overhead	Yes	7/29/17	13:28	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
249	PG&E	07/29/17	14:52	37.05999	-122.00113	Vegetation	Urban	< 0.25 Acres	Fire Agency	Scotts Valley Fire Dept.	101679068	PACIFIC BELL	21,000	Conductor	Overhead	Yes	7/29/17	14:52	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
250	PG&E	07/29/17	17:56	37.02507	-121.53583	Vegetation	Rural	< 3 Meters	Fire Agency	GEORGE MARSHALL	100610842	Unknown	21,000	Conductor	Overhead	Yes	7/29/17	17:56	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
251	PG&E	07/29/17	18:08	37.94875	-121.34571	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	102126507	Unknown	12,000	Conductor	Overhead	Yes	7/29/17	18:08	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
252	PG&E	07/29/17	20:45	35.45171	-120.61711	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Unknown	101941008	Unknown	0 - 750	Conductor	Overhead	Yes	7/29/17	20:45	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
253	PG&E	07/30/17	09:46	38.91318	-122.61768	Vegetation	Rural	< 0.25 Acres	Fire Agency	mike wlrk	102151066	None	0 - 750	Conductor	Overhead	Yes	7/30/17	09:46	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
254	PG&E	07/31/17	12:58	37.09707	-122.27965	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101679025	Unknown	0 - 750	Conductor	Overhead	No			Equipment/ Facility Failure	N.A.	N.A.	Unknown		
255	PG&E	07/31/17	14:10	35.97865	-120.11100	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	100695130	Unknown	21,000	Conductor	Overhead	Yes	7/31/17	14:10	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
256	PG&E	07/31/17	14:41	38.79675	-121.13288	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103782414	Unknown	12,000	Conductor	Overhead	Yes	7/31/17	14:41	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
257	PG&E	08/01/17	12:23	36.04123	-119.50529	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100661556	Unknown	0 - 750	Other	Overhead	Yes	8/1/17	12:23	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
258	PG&E	08/02/17	9:42	39.22744	-123.10811	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Pole 5/0	None	60,000	Conductor	Overhead	Yes	8/2/17	9:42	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
259	PG&E	08/02/17	5:54	40.79856	-123.39614	Vegetation	Rural	10 - 99 Acres	Fire Agency	Cal Fire	100974913	Unknown	12,000	Conductor	Overhead	Yes	8/2/17	5:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
260	PG&E	08/02/17	8:58	37.56179	-121.94860	Vegetation	Rural	< 0.25 Acres	Fire Agency	FREMONT FIRE DEPT. 91														

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Fire Suppressed by	Fire Suppressing Agency	Facility Identification	Utility Facility Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
274	PG&E	08/08/17	13:46	38.43664	-122.72596	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	Tower 005/090	None	115,000	Conductor	Overhead	Yes	8/8/17	13:46	Contact From Object	N.A.	Other	Electric Facility	Human Error	
275	PG&E	08/08/17	0:36	35.42687	-119.05719	Vegetation	Urban	< 0.25 Acres	Unknown	N.A.	100167715	PACIFIC BELL	12,000	Unknown	Subsurface	Yes	8/8/17	0:36	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
276	PG&E	08/08/17	4:10	38.49485	-122.66849	Vegetation	Rural	< 3 Meters	Fire Agency	911	102025742	PACIFIC BELL	12,000	Transformer	Overhead	Yes	8/8/17	4:10	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
277	PG&E	08/08/17	11:27	37.04448	-121.63431	Vegetation	Urban	< 3 Meters	Utility: PG&E	N.A.	100613200	VERIZON CALIFO	21,000	Capacitor Bank	Overhead	Yes	8/8/17	11:27	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
278	PG&E	08/08/17	20:35	37.26367	-119.71027	Vegetation	Rural	< 0.25 Acres	Fire Agency	TROY CHEEK1-209-966-3621	103793352	Unknown	0 – 750	Conductor	Overhead	Yes	8/8/17	20:35	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
279	PG&E	08/09/17	11:29	38.65323	-120.62732	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	114042496	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/9/17	11:29	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
280	PG&E	08/11/17	07:55	38.26485	-120.97476	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101253880	None	12,000	Conductor	Overhead	Yes	8/11/17	07:55	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
281	PG&E	08/12/17	09:08	34.66890	-120.02860	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103391912	Unknown	12,000	Conductor	Overhead	Yes	8/12/17	09:08	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	wire cut
282	PG&E	08/13/17	13:11	38.50939	-122.77004	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	101961046	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/13/17	13:11	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
283	PG&E	08/14/17	6:14	40.11642	-123.80645	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	100986364	Unknown	12,000	Conductor	Overhead	Yes	8/14/17	6:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
284	PG&E	08/14/17	23:52	37.12721	-122.16895	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Pole 015/127	None	60,000	Conductor	Overhead	Yes	8/14/17	23:52	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
285	PG&E	08/14/17	07:56	39.17938	-120.97608	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100083743	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/14/17	07:56	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
286	PG&E	08/15/17	19:28	39.50371	-121.27826	Vegetation	Rural	< 3 Meters	Unknown	N.A.	100396172	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/15/17	19:28	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
287	PG&E	08/16/17	20:24	35.78134	-119.91533	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	Span 0/6 to 0/7	None	70,000	Conductor	Overhead	Yes	8/16/17	20:24	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
288	PG&E	08/17/17	2:33	39.19342	-121.42271	Vegetation	Rural	< 0.25 Acres	Fire Agency	911	101304315	Unknown	12,000	Conductor	Overhead	Yes	8/17/17	2:33	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	pole cut down
289	PG&E	08/17/17	15:15	39.37033	-121.04842	Vegetation	Rural	< 0.25 Acres	Fire Agency	PHIL MICHAEL 265-2894	100083029	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/17/17	15:15	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
290	PG&E	08/18/17	17:09	37.09214	-121.66909	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100608897	VERIZON CALIFO	21,000	Conductor	Overhead	Yes	8/18/17	17:09	Other	N.A.	N.A.	N.A.	Human Error	CIP contractor
291	PG&E	08/19/17	11:31	37.68910	-121.25060	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102053834	Unknown	17,000	Conductor	Overhead	Yes	8/19/17	11:31	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
292	PG&E	08/19/17	21:16	40.57523	-122.29847	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101464623	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/19/17	21:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
293	PG&E	08/20/17	11:38	39.21636	-122.14087	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101634861	Unknown	12,000	Conductor	Overhead	Yes	8/20/17	11:38	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
294	PG&E	08/21/17	15:07	38.60798	-122.35312	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Aaron Latta 707 339 2918	102254922	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	8/21/17	15:07	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
295	PG&E	08/21/17	19:31	39.72577	-121.82052	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100341323	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/21/17	19:31	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
296	PG&E	08/22/17	14:17	38.49020	-122.89178	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102001687	Unknown	0 – 750	Conductor	Overhead	Yes	8/22/17	14:17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
297	PG&E	08/24/17	6:32	36.59050	-119.59286	Vegetation	Rural	< 3 Meters	Fire Agency	ca flu 012333	100897456	Unknown	12,000	Conductor	Overhead	Yes	8/24/17	6:32	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
298	PG&E	08/25/17	9:47	39.02509	-121.57752	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101314075	Unknown	21,000	Conductor	Overhead	Yes	8/25/17	9:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
299	PG&E	08/26/17	7:10	38.82516	-121.39528	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100101888	Unknown	0 – 750	Conductor	Overhead	Yes	8/26/17	7:10	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
300	PG&E	08/26/17	20:39	38.47073	-122.64717	Vegetation	Urban	< 3 Meters	Fire Agency	Santa Rosa Fire Dept	101966474	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/26/17	20:39	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
301	PG&E	08/26/17	20:53	38.70657	-121.01929	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101382231	Unknown	0 – 750	Conductor	Overhead	Yes	8/26/17	20:53	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
302	PG&E	08/27/17	18:11	37.99158	-121.34788	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	Unknown	103193823	Unknown	21,000	Conductor	Overhead	Yes	8/27/17	18:11	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
303	PG&E	08/27/17	20:04	38.91654	-121.15100	Vegetation	Rural	< 0.25 Acres	Fire Agency	530-477-0641 x7, log 22629	100077184	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/27/17	20:04	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
304	PG&E	08/27/17	22:16	37.35848	-120.85030	Vegetation	Rural	< 0.25 Acres	Fire Agency	CHRIS ALLEN 209-634-7086	103346364	Unknown	12,000	Conductor	Overhead	Yes	8/27/17	22:16	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
305	PG&E	08/28/17	6:32	35.42183	-119.03040	Vegetation	Urban	< 0.25 Acres	Fire Agency	BCFD/KCFD 661-324-6551	103139674	Unknown	0 – 750	Conductor	Overhead	Yes	8/28/17	6:32	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
306	PG&E	08/28/17	8:36	35.72450	-119.53414	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	100171751	Unknown	12,000	Conductor	Overhead	Yes	8/28/17	8:36	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
307	PG&E	08/28/17	9:14	38.74430	-122.64906	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	103781085	Unknown	0 – 750	Conductor	Overhead	Yes	8/28/17	9:14	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
308	PG&E	08/28/17	10:07	39.04720	-120.78569	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	FORESTHILL	100019525	Unknown	12,000	Conductor	Overhead	Yes	8/28/17	10:07	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
309	PG&E	08/28/17	13:55	37.68570	-120.80670	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	103237313	None	0 – 750	Conductor	Overhead	Yes	8/28/17	13:55	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
310	PG&E	08/28/17	14:06	38.63402	-122.41945	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	102253236	Unknown	21,000	Conductor	Overhead	Yes	8/28/17	14:06	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
311	PG&E	08/28/17	14:23	38.50540	-120.75916	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101260228	PACIFIC BELL	12,000	Fuse	Overhead	Yes	8/28/17	14:23	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
312	PG&E	08/28/17	14:59	40.28528	-123.87278	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100990599	Unknown	12,000	Conductor	Overhead	Yes	8/28/17	14:59	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
313	PG&E	08/28/17	23:56	40.11971	-123.64400	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	103844288	Unknown	12,000	Conductor	Overhead	Yes	8/28/17	23:56	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
314	PG&E	08/29/17	6:08	38.23650	-122.46080	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101998998	Unknown	12,000	Conductor	Overhead	Yes	8/29/17	6:08	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
315	PG&E	08/29/17	10:27	38.36871	-122.00121	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	101661402	PACIFIC BELL	12,000	Lightning Arrestor	Overhead	Yes	8/29/17	10:27	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
316	PG&E	08/29/17	10:40	38.20657	-121.15763	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	102082031	Unknown	12,000	Conductor	Overhead	Yes	8/29/17	10:40	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
317	PG&E	08/29/17	12:49	37.45070	-119.64538	Vegetation	Rural	> 5000 Acres	Fire Agency	USFS	101017368	Unknown	12,000	Conductor	Overhead	Yes	8/29/17	12:49	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	PG&E contractor
318	PG&E	08/29/17	15:54	38.30196	-122.54314	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	911	102026119	PACIFIC BELL	12,000	Fuse	Overhead	Yes	8/29/17	15:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
319	PG&E	08/30/17	16:17	35.35283	-119.05377	Vegetation	Urban	< 0.25 Acres	Fire Agency	BCFD/KCFD 661-324-6551	100145928	Unknown	0 – 750	Conductor	Overhead	Yes	8/30/17	16:17	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
320	PG&E	08/30/17	18:21	40.62430	-122.30386	Vegetation	Rural	< 0.25 Acres	Fire Agency	CASHU008896	103151338	YES	12,000	Conductor	Overhead	Yes	8/30/17	18:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
321	PG&E	08/30/17	22:37	38.99933	-120.98871	Vegetation	Rural	< 3 Meters	Fire Agency	Andy 530-889-0111	100026238	PACIFIC BELL	12,000	Conductor	Overhead	Yes	8/30/17	22:37	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
322	PG&E	08/30/17	22:39	38.16621	-121.93815	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	suisun	103850994	Unknown	12,000	Conductor	Overhead	Yes	8/30/17	22:39	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
323	PG&E	08/31/17	6:42	35.61599	-120.85770	Vegetation	Rural	< 0.25 Acres	Fire Agency	Derrick	101860075	Unknown	21,000	Conductor	Overhead	Yes	8/31/17	6:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
324	PG&E	08/31/17	11:33	37.13788	-121.99658	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100519201	Unknown	21,000	Conductor	Overhead	Yes	8/31/17	11:33	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
325	PG&E	08/31/17	11:51	38.38169	-122.31951	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102291943	PACIFIC BELL	21,000	Conductor	Overhead	Yes	8/31/17	11:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
326	PG&E	08/31/17	21:07	41.06048	-124.10371	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100977438	Unknown	12,000	Conductor										

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Utility Facility Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
345	PG&E	09/05/17	1:24	39.43168	-121.55285	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100420238	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/5/17	1:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
346	PG&E	09/05/17	6:58	39.67273	-123.51279	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	102194697	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	9/5/17	6:58	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
347	PG&E	09/05/17	7:20	39.71095	-121.79724	Vegetation	Rural	< 3 Meters	Fire Agency	{530} 538-6841	100355255	Unknown	12,000	Conductor	Overhead	Yes	9/5/17	7:20	Wire-Wire Contact	N.A.	Vegetation	N.A.	Unknown	
348	PG&E	09/05/17	13:51	38.18972	-121.31746	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103218208	Unknown	12,000	Conductor	Overhead	Yes	9/5/17	13:51	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
349	PG&E	09/06/17	17:51	38.34987	-122.25777	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102284869	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/5/17	17:51	Equipment/ Facility Failure	Conductor	N.A.	Vegetation	Unknown	
350	PG&E	09/06/17	19:26	40.83920	-122.36350	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103643183	Unknown	12,000	Conductor	Overhead	Yes	9/6/17	19:26	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
351	PG&E	09/06/17	20:08	37.29255	-122.29403	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100256917	Unknown	12,000	Conductor	Overhead	Yes	9/6/17	20:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
352	PG&E	09/08/17	4:47	38.74778	-120.85905	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101391575	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/8/17	4:47	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
353	PG&E	09/08/17	17:21	38.60388	-120.92748	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101379094	PACIFIC BELL	21,000	Conductor	Overhead	Yes	9/8/17	17:21	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
354	PG&E	09/08/17	21:14	37.96038	-120.37636	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	John Life 209-984-5623	101042521	Unknown	17,000	Conductor	Overhead	Yes	9/8/17	21:14	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
355	PG&E	09/09/17	18:36	36.66181	-121.54766	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101769870	Unknown	12,000	Conductor	Overhead	Yes	9/9/17	18:36	Equipment/ Facility Failure	Conductor	N.A.	Other	Unknown	
356	PG&E	09/10/17	1:22	39.25988	-121.49023	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	TYLER LOPEZ	101289867	None	12,000	Conductor	Overhead	Yes	9/10/17	1:22	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
357	PG&E	09/10/17	16:30	37.30393	-120.52747	Vegetation	Rural	10 - 9.9 Acres	Fire Agency	Merced County FD	101161316	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	9/10/17	16:30	Equipment/ Facility Failure	Conductor	N.A.	Other	Unknown	
358	PG&E	09/11/17	7:18	37.00083	-121.66674	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100621936	VERIZON CALIFO	0 – 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
359	PG&E	09/11/17	8:50	36.95146	-121.84204	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101790954	PACIFIC BELL	21,000	Fuse	Overhead	Yes	9/11/17	8:50	Contact From Object	N.A.	Other	Electric Facility	Weather	lightning strike
360	PG&E	09/11/17	23:50	40.86724	-124.08827	Vegetation	Urban	< 3 Meters	Fire Agency	BOB	100964579	Unknown	12,000	Conductor	Overhead	Yes	9/11/17	23:50	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
361	PG&E	09/12/17	9:24	39.74095	-121.60787	Vegetation	Rural	< 0.25 Acres	Fire Agency		100330302	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/12/17	9:24	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
362	PG&E	09/12/17	17:18	39.45106	-121.60519	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	tom klage 530 538-7888	100419482	Unknown	12,000	Conductor	Overhead	Yes	9/12/17	17:18	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
363	PG&E	09/14/17	11:02	39.11112	-121.55647	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101320308	None	12,000	Switch	Overhead	Yes	9/14/17	11:02	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
364	PG&E	09/14/17	12:09	39.50393	-121.54528	Vegetation	Urban	< 0.25 Acres	Fire Agency	530-538-2448	100372805	Unknown	12,000	Conductor	Overhead	Yes	9/14/17	12:09	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
365	PG&E	09/14/17	14:06	40.29421	-123.81736	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100989497	Unknown	12,000	Conductor	Overhead	Yes	9/14/17	14:06	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
366	PG&E	09/15/17	14:55	39.74607	-121.48853	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100335239	Unknown	12,000	Conductor	Overhead	Yes	9/15/17	14:55	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
367	PG&E	09/17/17	15:05	36.64729	-119.38613	Vegetation	Rural	< 3 Meters	Customer	N.A.	100738741	VERIZON CALIFO	0 – 750	Conductor	Overhead	Yes	9/17/17	15:05	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
368	PG&E	09/17/17	17:38	38.99459	-121.02607	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100029537	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/17/17	17:38	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
369	PG&E	09/18/17	13:01	39.38885	-121.40538	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	103795057	Unknown	0 – 750	Conductor	Overhead	Yes	9/18/17	13:01	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
370	PG&E	09/18/17	15:10	39.60135	-122.05551	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103849874	Unknown	12,000	Conductor	Overhead	Yes	9/18/17	15:10	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
371	PG&E	09/18/17	18:01	38.21975	-122.54300	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	101997149	Unknown	12,000	Conductor	Overhead	Yes	9/18/17	18:01	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
372	PG&E	09/18/17	19:01	38.07423	-122.82861	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	102229215	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/18/17	19:01	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
373	PG&E	09/18/17	23:50	37.90879	-120.48652	Vegetation	Rural	10 - 9.9 Acres	Fire Agency	incident comander geoff marshall 209-419-4407	101040882	Unknown	17,000	Conductor	Overhead	Yes	9/18/17	23:50	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
374	PG&E	09/19/17	19:13	35.47836	-119.29591	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	10207112	Unknown	12,000	Conductor	Overhead	Yes	9/19/17	19:13	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
375	PG&E	09/20/17	2:06	37.25968	-122.32223	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100322388	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/20/17	2:06	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
376	PG&E	09/20/17	8:41	36.94037	-120.90142	Vegetation	Rural	10 - 9.9 Acres	Fire Agency	Cal Fire	Pole 2/6 - Arbunua Tap	None	70,000	Conductor	Overhead	Yes	9/20/17	8:41	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
377	PG&E	09/21/17	8:39	39.61470	-121.72582	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	100347380	Unknown	0 – 750	Conductor	Overhead	Yes	9/21/17	8:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
378	PG&E	09/22/17	14:28	36.09612	-120.05766	Vegetation	Rural	< 0.25 Acres	Fire Agency	SAME AS TAG. FD NOT STANDING BY UPON ARRIVAL	100663084	Unknown	12,000	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
379	PG&E	09/23/17	9:16	37.01287	-120.62562	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101181497	Unknown	12,000	Conductor	Overhead	Yes	9/23/17	9:16	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
380	PG&E	09/23/17	14:17	40.65090	-122.29740	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	DAREN STEWART 448-2421	101467221	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/23/17	14:17	Contact From Object	N.A.	Vegetation	Electric Facility	Human Error	Third-party caused
381	PG&E	09/24/17	2:13	38.10480	-120.98901	Vegetation	Rural	10 - 9.9 Acres	Fire Agency	Cal Fire	Pole 016/297	Unknown	60,000	Conductor	Overhead	Yes	9/24/17	2:13	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
382	PG&E	09/24/17	7:54	37.40140	-122.02740	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100515206	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/24/17	7:54	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
383	PG&E	09/24/17	16:42	38.38690	-122.96670	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	DOUG JONES	101973946	PACIFIC BELL	12,000	Conductor	Overhead	Yes	9/24/17	16:42	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
384	PG&E	09/25/17	19:49	36.81370	-121.72098	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	Tower 058/249	Unknown	230,000	Conductor	Overhead	Yes	9/25/17	19:49	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
385	PG&E	09/26/17	17:44	38.06427	-122.80563	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Unknown	102228291	Unknown	12,000	Other	Overhead	Yes	9/26/17	17:44	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
386	PG&E	09/27/17	9:11	39.01626	-122.86854	Vegetation	Rural	< 3 Meters	Customer	N.A.	102143577	PACIFIC BELL	12,000	Transformer	Overhead	Yes	9/27/17	9:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
387	PG&E	09/27/17	12:12	39.48450	-121.35450	Vegetation	Rural	< 0.25 Acres	Fire Agency	bill lopez cell 530 521-8052	100429924	PACIFIC BELL	12,000	Fuse	Overhead	Yes	9/27/17	12:12	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
388	PG&E	09/27/17	19:06	40.75920	-123.99500	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	103660812	Unknown	12,000	Conductor	Overhead	Yes	9/27/17	19:06	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
389	PG&E	09/28/17	18:28	37.98840	-122.09700	Vegetation	Urban	< 3 Meters	Fire Agency	(510)374-7070	103627505	Unknown	21,000	Conductor	Overhead	Yes	9/28/17	18:28	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
390	PG&E	09/29/17	2:01	39.53174	-122.18567	Vegetation	Urban	< 3 Meters	Unknown	N.A.	100419384	Unknown	21,000	Transformer	Padmounted	Yes	9/29/17	2:01	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
391	PG&E	09/30/17	15:08	37.41091	-121.17474	Vegetation	Rural	10 - 9.9 Acres	Fire Agency	Cal Fire	Tower 030/132	None	230,000	Conductor	Overhead	Yes	9/30/17	15:08	Vandalism/Theft	N.A.	N.A.	N.A.	Human Error	Third-party caused
392	PG&E	10/01/17	7:24	37.91400	-122.37710	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101437028	Unknown	12,000	Transformer	Overhead	Yes	10/1/17	7:24	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
393	PG&E	10/01/17	16:11	39.79696	-122.11853	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103850270	Unknown	0 – 750	Conductor	Overhead	Yes	10/1/17	16:11	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
394	PG&E	10/01/17	23:51	40.01920	-122.14520	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	MARK FRITZ	101534592	Unknown	12,000	Conductor	Overhead	Yes	10/1/17	23:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
395	PG&E	10/02/17	2:55	37.33137	-120.52428	Vegetation	Urban	26 - 9.99 Acres	Fire Agency	209-966-3621	101160137	Unknown	12,000	Conductor	Overhead	Yes	10/2/17	2:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
396	PG&E	10/02/17	7:07	38.29490	-122.10660	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101658181	Unknown	12,000	Transformer	Overhead	Yes	10/2/17	7:07	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
397	PG&E	10/02/17	12:22	39.63135	-122.00685	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	103224422	Unknown	12,000	Conductor	Overhead	Yes	10/2/17	12:22	Contact From Object					

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

1	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
2	Utility Name	Fire Start Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Fire Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
418	PG&E	10/08/17	21:46	39.25949	-120.99650	Vegetation	Urban	< 0.25 Acres	Fire Agency	PHILLIP NUNNICK 530 273-3158 INCIDENT # 26264	100072730	PACIFIC BELL	12,000	Other	Overhead	Yes	10/8/17	21:46	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
419	PG&E	10/08/17	22:19	39.73711	-121.64642	Vegetation	Rural	< 3 Meters	Fire Agency	911	103319605	Unknown	0 – 750	Conductor	Overhead	Yes	10/8/17	22:19	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
420	PG&E	10/08/17	22:30	38.32262	-121.94307	Vegetation	Rural	< 0.25 Acres	Fire Agency	vaca	101561309	PACIFIC BELL	21,000	Conductor	Overhead	Yes	10/8/17	22:30	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
421	PG&E	10/08/17	22:54	35.55276	-118.96809	Vegetation	Rural	< 3 Meters	Unknown	N.A.	10068104	PACIFIC BELL	115,000	Conductor	Overhead	Yes	10/8/17	22:54	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
422	PG&E	10/08/17	22:58	39.36423	-121.11307	Vegetation	Rural	< 3 Meters	Fire Agency	INCIDENT NUMBER 26268	100068104	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/8/17	22:58	Contact From Object	N.A.	Electric Facility	Weather	Oct 8/9 wind storm	
423	PG&E	10/08/17	23:51	38.27585	-121.96167	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	707-428-7305	101680727	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	10/8/17	23:51	Wire-Wire Contact	N.A.	N.A.	Unknown		
424	PG&E	10/09/17	1:02	38.70368	-120.67250	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	101408485	Unknown	21,000	Other	Overhead	Yes	10/9/17	1:02	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
425	PG&E	10/09/17	1:13	38.10103	-122.21965	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	102218775	PACIFIC BELL	0 – 750	Conductor	Overhead	No			Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
426	PG&E	10/09/17	1:25	38.19062	-121.94974	Vegetation	Rural	10 - 99 Acres	Unknown	N.A.	101559973	Unknown	21,000	Conductor	Overhead	Yes	10/9/17	1:25	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
427	PG&E	10/09/17	1:29	37.84157	-121.95827	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100501933	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	10/9/17	1:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
428	PG&E	10/09/17	1:45	38.85755	-122.72207	Vegetation	Rural	< 0.25 Acres	Fire Agency	wink	103570679	Unknown	12,000	Conductor	Overhead	Yes	10/9/17	1:45	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
429	PG&E	10/09/17	2:27	37.72931	-122.13783	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100903727	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/9/17	2:27	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
430	PG&E	10/09/17	4:36	38.26428	-122.04877	Vegetation	Urban	< 3 Meters	Fire Agency	Fairfield	101660707	Unknown	0 – 750	Conductor	Overhead	Yes	10/9/17	4:36	Contact From Object	N.A.	Vegetation	Electric Facility	Weather	Oct 8/9 wind storm
431	PG&E	10/09/17	12:05	35.40672	-118.96231	Vegetation	Urban	< 3 Meters	Customer	N.A.	100252698	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	10/9/17	12:05	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
432	PG&E	10/10/17	13:36	38.93098	-123.30235	Vegetation	Rural	< 3 Meters	Customer	N.A.	102214553	Unknown	0 – 750	Conductor	Overhead	Yes	10/10/17	13:36	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
433	PG&E	10/10/17	16:17	38.31478	-122.70673	Vegetation	Urban	.26 - 9.99 Acres	Unknown	N.A.	101996286	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	10/10/17	16:17	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
434	PG&E	10/10/17	16:29	37.25591	-121.95862	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100542800	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	10/10/17	16:29	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
435	PG&E	10/11/17	11:57	38.50153	-123.02367	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101974930	Unknown	12,000	Conductor	Overhead	Yes	10/11/17	11:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
436	PG&E	10/11/17	16:41	38.67900	-121.94870	Vegetation	Rural	< 3 Meters	Fire Agency	ESPARTO FIRE PROTECTION DISTRICT- (630) 787-3300	101591668	Unknown	0 – 750	Conductor	Overhead	Yes	10/11/17	16:41	Unknown	N.A.	N.A.	N.A.	Unknown	
437	PG&E	10/13/17	8:30	38.02343	-122.83764	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	102248021	Unknown	0 – 750	Transformer	Overhead	Yes	10/13/17	8:30	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
438	PG&E	10/13/17	10:27	37.05607	-122.02057	Vegetation	Urban	< 0.25 Acres	Fire Agency	Scotts Valley Fire Dept.	101677721	Unknown	21,000	Conductor	Overhead	Yes	10/13/17	10:27	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
439	PG&E	10/13/17	19:15	36.94153	-120.03973	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101224900	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/13/17	19:15	Contact From Object	N.A.	Vehicle	Pole	Human Error	Third-party caused
440	PG&E	10/13/17	22:19	39.76485	-121.63075	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100325368	PACIFIC BELL	0 – 750	Transformer	Overhead	Yes	10/13/17	22:19	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
441	PG&E	10/14/17	8:37	37.39437	-122.09155	Building	Urban	Structure Only	Fire Agency	Unknown	100513237	PACIFIC BELL	12,000	Transformer	Overhead	Yes	10/14/17	8:37	Equipment/ Facility Failure	Transformer	N.A.	N.A.	Unknown	
442	PG&E	10/14/17	14:43	40.11215	-122.17368	Vegetation	Rural	< 0.25 Acres	Self Extinguished	N.A.	101539953	None	12,000	Fuse	Overhead	Yes	10/14/17	14:43	Equipment/ Facility Failure	Pole	N.A.	N.A.	Unknown	
443	PG&E	10/15/17	13:15	37.38553	-121.81327	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	SA JOSE FD	100563705	Unknown	12,000	Conductor	Overhead	Yes	10/15/17	13:15	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
444	PG&E	10/16/17	12:10	36.58307	-121.93676	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101781248	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/16/17	12:10	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
445	PG&E	10/16/17	12:20	37.71998	-122.06870	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100900970	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	10/16/17	12:20	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
446	PG&E	10/16/17	12:26	36.66410	-121.09947	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Nick Shawkey E4462 209-402-1645 Cover Engine from Tuolumne Calaveras Unit	101689865	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	10/16/17	12:26	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
447	PG&E	10/17/17	18:22	35.42566	-119.02972	Vegetation	Urban	< 3 Meters	Self Extinguished	N.A.	100144662	PACIFIC BELL	12,000	Capacitor Bank	Overhead	Yes	10/17/17	18:22	Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	
448	PG&E	10/18/17	13:58	37.63605	-122.07925	Vegetation	Urban	< 3 Meters	Fire Agency	Unknown	100952408	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	10/18/17	13:58	Contact From Object	N.A.	Vehicle	N.A.	Human Error	
449	PG&E	10/20/17	5:59	36.74749	-119.76295	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	100859697	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	5:59	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
450	PG&E	10/20/17	6:18	39.29221	-121.01573	Vegetation	Rural	< 3 Meters	Fire Agency	PHILLIP NUNNINK INCIDENT # 27272	100087647	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/20/17	6:18	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
451	PG&E	10/20/17	9:06	36.03599	-120.05797	Vegetation	Rural	300 - 999 Acres	Fire Agency	Unknown	Pole 009/009	Unknown	70,000	Conductor	Overhead	Yes	10/20/17	9:06	Contact From Object	N.A.	Other	Electric Facility	Other	bird's nest
452	PG&E	10/20/17	13:43	35.35300	-119.98730	Vegetation	Rural	10 - 99 Acres	Fire Agency	Kevin McLean Office(805)593-3421, Cell(805)903-3421	100136483	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	13:43	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
453	PG&E	10/20/17	13:45	34.55317	-120.53029	Vegetation	Rural	100 - 299 Acres	Fire Agency	Unknown	101921492	Unknown	12,000	Conductor	Overhead	Yes	10/20/17	13:45	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
454	PG&E	10/20/17	14:00	36.92155	-119.72828	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100727124	Unknown	21,000	Fuse	Overhead	Yes	10/20/17	14:00	Equipment/ Facility Failure	Other	N.A.	N.A.	Unknown	
455	PG&E	10/21/17	15:08	39.06400	-122.77645	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102155186	PACIFIC BELL	12,000	Conductor	Overhead	Yes	10/21/17	15:08	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
456	PG&E	10/21/17	16:05	37.59108	-122.00995	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Unknown	103516949	Unknown	0 – 750	Conductor	Overhead	Yes	10/21/17	16:05	Contact From Object	N.A.	Balloons	Electric Facility	Human Error	Third-party caused
457	PG&E	10/23/17	19:34	36.07720	-121.01900	Vegetation	Rural	< 0.25 Acres	Customer	N.A.	101763398	Unknown	12,000	Conductor	Overhead	Yes	10/23/17	19:34	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
458	PG&E	10/23/17	21:24	37.37133	-122.34799	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	100270421	Unknown	12,000	Conductor	Overhead	Yes	10/23/17	21:24	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
459	PG&E	10/24/17	15:23	36.85988	-121.79474	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	101789001	PACIFIC BELL	21,000	Conductor	Overhead	Yes	10/24/17	15:23	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
460	PG&E	10/26/17	10:53	36.40356	-121.91219	Vegetation	Urban	.26 - 9.99 Acres	Fire Agency	Cal Fire	101777002	Unknown	12,000	Conductor	Overhead	Yes	10/26/17	10:53	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
461	PG&E	10/28/17	15:26	39.45162	-123.38381	Vegetation	Rural	< 3 Meters	Fire Agency	Cal Fire	102209084	Unknown	12,000	Conductor	Overhead	Yes	10/28/17	15:26	Contact From Object	N.A.	Vehicle	Communication Facility	Human Error	
462	PG&E	10/28/17	20:08	35.02222	-118.76915	Vegetation	Rural	< 0.25 Acres	Unknown	N.A.	100223850	Unknown	12,000	Fuse	Overhead	Yes	10/28/17	20:08	Equipment/ Facility Failure	Fuse	N.A.	N.A.	Unknown	
463	PG&E	10/31/17	18:56	39.00345	-121.69065	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	Pole 010/208	Unknown	60,000	Conductor	Overhead	Yes	10/31/17	18:56	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
464	PG&E	10/31/17	21:02	39.11189	-122.91633	Vegetation	Rural	< 0.25 Acres	Fire Agency	Cal Fire	Structure 020/003	Unknown	60,000	Conductor	Overhead	Yes	10/31/17	21:02	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
465	PG&E	11/06/17	9:59	37.14600	-121.66753	Vegetation	Rural	< 0.25 Acres	Fire Agency	INCIDENT # 1717CASC008183	103570543	YES	21,000	Conductor	Overhead	Yes	11/6/17	9:59	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
466	PG&E	11/06/17	15:06	38.29980	-122.50300	Vegetation	Urban	< 0.25 Acres	Fire Agency	Unknown	101982913	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/6/17	15:06	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
467	PG&E	11/08/17	07:11	37.73669	-120.34587	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	101191714	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/8/17	07:11	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
468	PG&E	11/08/17	14:53	37.79198	-122.22211	Building	Urban	Structure Only	Fire Agency	Unknown	101352529	Unknown	4,000	Conductor	Overhead	Yes	11/8/17	14:53	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
469	PG&E	11/11/17	11:57	35.11908	-120.39364	Vegetation	Rural	< 0.25 Acres	Fire Agency	Jordan Dayley ph#929-3911,engine#3467	101931190	PACIFIC BELL	12,000	Conductor	Overhead	Yes	11/11/17	11:57	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
470	PG&E	11/12/17	19:44	36.73779	-119.77691	Building	Urban	< 0.25 Acres</																

Pacific Gas and Electric Company - Fire Incident Data Collection Plan
Annual Report for 2017

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X
1	Fire Start			Location			Fire			Utility Facility			Outage			Field Observations								
2	Utility Name	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	Notes (Optional):
486	PG&E	12/12/17	4:40	39.77107	-121.59727	Building	Urban	Structure Only	Fire Agency	paradise fire city department	100324902	PACIFIC BELL	12,000	Fuse	Overhead	Yes	12/12/17	4:40	Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
487	PG&E	12/13/17	12:13	35.59220	-120.64741	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103390807	Unknown	21,000	Other	Overhead	Yes	12/13/17	12:13	Equipment/ Facility Failure	Recloser	N.A.	N.A.	Unknown	
488	PG&E	12/14/17	1:33	37.19789	-121.83746	Building	Rural	Structure Only	Fire Agency	Unknown	100622323	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	12/14/17	1:33	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
489	PG&E	12/14/17	17:16	34.58763	-120.35663	Vegetation	Rural	10 - 99 Acres	Fire Agency	Unknown	101911004	VERIZON CALIFO	12,000	Conductor	Overhead	Yes	12/14/17	17:16	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
490	PG&E	12/16/17	7:01	39.74474	-122.19612	Building	Urban	Structure Only	Fire Agency	ORLAND CITY FIRE DEPT	100428554	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	12/16/17	7:01	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
491	PG&E	12/16/17	11:51	38.81706	-122.70412	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Shawn Ohare	102167231	PACIFIC BELL	12,000	Conductor	Overhead	Yes	12/16/17	11:51	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
492	PG&E	12/16/17	13:39	37.97022	-121.64092	Vegetation	Rural	< 0.25 Acres	Fire Agency	FIRE CAPTAIN ON DUTY	100473121	PACIFIC BELL	0 – 750	Conductor	Overhead	Yes	12/16/17	13:39	Equipment/ Facility Failure	Splice/Clamp/Connector	N.A.	N.A.	Unknown	
493	PG&E	12/16/17	16:03	35.65929	-120.49459	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	103131190	Unknown	21,000	Conductor	Overhead	Yes	12/16/17	16:03	Other	N.A.	N.A.	Unknown		
494	PG&E	12/19/17	7:05	36.27152	-120.39270	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	100745841	Unknown	12,000	Fuse	Overhead	Yes	12/19/17	7:05	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
495	PG&E	12/19/17	16:55	35.23093	-119.59840	Vegetation	Rural	< 0.25 Acres	Fire Agency	KC FIRE DEPT	100165540	Unknown	21,000	Conductor	Overhead	Yes	12/19/17	16:55	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
496	PG&E	12/19/17	19:45	40.72710	-122.32629	Vegetation	Rural	< 0.25 Acres	Fire Agency	Unknown	101457738	Unknown	0 – 750	Conductor	Overhead	Yes	12/19/17	19:45	Equipment/ Facility Failure	Conductor	N.A.	N.A.	Unknown	
497	PG&E	12/20/17	07:54	37.40115	-122.36062	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	100318864	PACIFIC BELL	12,000	Conductor	Overhead	Yes	12/20/17	07:54	Contact From Object	N.A.	Vegetation	Electric Facility	Unknown	
498	PG&E	12/20/17	14:03	35.66460	-121.24400	Vegetation	Rural	.26 - 9.99 Acres	Fire Agency	Cal Fire	103857828	Unknown	12,000	Fuse	Overhead	No			Equipment/ Facility Failure	Insulator	N.A.	N.A.	Unknown	
499	PG&E	12/20/17	16:04	34.61055	-120.32180	Vegetation	Rural	< 3 Meters	Fire Agency	Unknown	101906902	VERIZON CALIFO	12,000	Fuse	Overhead	Yes	12/20/17	16:04	Equipment/ Facility Failure	Crossarm	N.A.	N.A.	Unknown	
500	PG&E	12/22/17	14:38	35.33754	-119.06370	Building	Urban	Structure Only	Fire Agency	Unknown	5895SW	Unknown	21,000	Switch	Subsurface	Yes	12/22/17	14:38	Equipment/ Facility Failure	Switch	N.A.	N.A.	Unknown	
501	PG&E	12/24/17	6:41	37.44444	-122.18976	Building	Urban	Structure Only	Fire Agency	Menlo Park FD	103511827	Unknown	4,000	Conductor	Overhead	Yes	12/24/17	6:41	Contact From Object	N.A.	Animal	Electric Facility	Unknown	
502	PG&E	12/24/17	03:53	40.46185	-122.32768	Vegetation	Rural	< 3 Meters	Self Extinguished	N.A.	101496394	Unknown	12,000	Conductor	Overhead	Yes	12/24/17	03:53	Contact From Object	N.A.	Vehicle	Electric Facility	Human Error	Third-party caused
503	PG&E	12/29/17	16:31	37.85168	-122.15863	Vegetation	Rural	< 3 Meters	Fire Agency	925-933-1313	100488954	PACIFIC BELL	12,000	Capacitor Bank	Overhead	No			Equipment/ Facility Failure	Capacitor Bank	N.A.	N.A.	Unknown	

CPUC Sample Interactive

Outage			Suspected Cause					Notes (Optional):
Was There an Outage	Date	Time	Suspected Ignition Cause	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor	
Yes	6/16/12	13:30	Contact Between Third Party Facility on Pole and Supply Lines				Weather	
No			Contact From Object		Animal	Communication Facility	Human Error	
			Contact From Object		Balloons	Electric Facility	Unknown	
			Contact From Object		Other	Pole	Outside Force	
			Contact From Object		Vegetation	Pole	Other	
			Contact From Object		Vehicle	Pole		
			Contamination					
			Equipment/Facility Failure	Capacitor Bank				
			Equipment/Facility Failure	Conductor				
			Equipment/Facility Failure	Fuse				
			Equipment/Facility Failure	Insulator				
			Equipment/Facility Failure	Lightning Arrestor				
			Equipment/Facility Failure	Pole				
			Equipment/Facility Failure	Guy/Span Wire				
			Equipment/Facility Failure	Other				
			Equipment/Facility Failure	Protective Relay				
			Equipment/Facility Failure	Crossarm				
			Equipment/Facility Failure	Recloser				
			Equipment/Facility Failure	Sectionalizer				
			Equipment/Facility Failure	Splice/Clamp/Connector				
			Equipment/Facility Failure	Switch				
			Equipment/Facility Failure	Transformer				
			Equipment/Facility Failure	Voltage Regulator				
			Normal Operation					
			Other					
			Unknown					
			Vandalism/Theft					
			Wire-Wire Contact					

[illegible]